



## E. Coli Positive - Repeat Sampling Requirements - 08-03-21

1 message

**Delgado - CDPHE, Jorge** <jorge.a.delgado@state.co.us>

Tue, Aug 3, 2021 at 1:22 PM

To: DCHAPMAN@englewoodco.gov

Cc: "Pohl, Robert" <robert.pohl@state.co.us>, Tyson Ingels - CDPHE <tyson.ingels@state.co.us>, Chelsea Cotton - CDPHE <chelsea.cotton@state.co.us>, Bryan Pilson - CDPHE <bryan.pilson@state.co.us>

Mr. Champman,

Thank you for taking my phone call today. As we discussed, a water sample collected from ENGLEWOOD CITY OF (CO0103045) ("System") on 08/02/2021 has results showing total coliform bacteria and E. coli.

The System is now required to collect 3 total coliform repeat samples in the distribution system on or before 08/04/2021. For every routine positive, 1 repeat must be collected at the original positive tap, 1 upstream within 5 service connections, and 1 downstream within 5 service connections. Please note that the originating positive sample tap must be collected.

In the event that a presence for total or coliform is detected in any of the repeat samples, a boils water notice would be issued by the department. As I mentioned since this is an E. Coli. positive sample, the department will send a follow-up correspondence requesting additional information and may request a meeting to discuss potential emergency response procedures and department expectations.

You indicated that the sample location was in Zone 2 however the sampling location of the TC positive did not appear to be in Zone 2 based on the department's preliminary observation. Please provide a map of the Zone and the location of the positive sample result.

More to follow.

--

**Jorge A. Delgado Jr, PE**

Unit Manager

Drinking Water Compliance Assurance Section

Pronouns: he, him, his ([Why?](#))



**COLORADO**  
**Water Quality Control Division**  
Department of Public Health & Environment

**C: 303.859.1806** | O: 303.692.3511 | F: 303.758.1398

4300 Cherry Creek Drive South, Denver, CO 80246

[jorge.a.delgado@state.co.us](mailto:jorge.a.delgado@state.co.us) | [wqcdcompliance.com](http://wqcdcompliance.com)

24-Hour Emergency: [1-877-518-5608](tel:1-877-518-5608) | Acute Drinking Water Situations: [303-692-3308](tel:303-692-3308):

Total Coliform Positive, Nitrate, Nitrite Chlorine Dioxide MCL Exceedances or Improperly Filtered or Disinfected Surface Water or Backflow Contamination Event

Please use this [Meeting Request Form](#) to schedule any necessary phone calls.

**POWER**  
THE COMEBACK

**Get your**  
**COVID-19 vaccine.**

**COCOVACCINE.org** | **1-877-CO VAX CO**

Your feedback is important to us! Please [let us know](#) how I am doing.

Please consider the environment before printing this e-mail.