



August 4, 2021 3:10 PM

DAVID CHAPMAN
ENGLEWOOD CITY OF - PWSID CO0103045
1500 W LAYTON AVE
ENGLEWOOD CO 80110

BOIL/BOTTLE WATER ADVISORY - TIER 1 PUBLIC NOTIFICATION REQUIREMENT

Dear DAVID CHAPMAN:

This letter serves as formal notification to the ENGLEWOOD CITY OF (the "Supplier") by the Colorado Department of Public Health and Environment-Water Quality Control Division (the "Department") of the requirement to issue a "Boil/Bottle Water Advisory" to the users of the public water system. This "Boil/Bottle Water Advisory" is required as a measure to protect public health due to **the presence of E. coli in distribution system.**

Section 11.33 of Regulation 11: Colorado Primary Drinking Water Regulations 5 CCR 1002-11 (Regulation 11) requires that public notice be delivered to the Supplier's water users as soon as practical and within **twenty-four (24) hours** of receipt of this letter. Per consultation with the supplier, the department is reviewing a press release that will be issued prior to 430PM on August 4, 2021.

To assist you in fulfilling the public notification requirements, enclosed are copies of the Tier 1 Public Notice Instructions, which includes the "Ten Required Elements of a Public Notice", the Public Notification Template, and the Drinking Water Public Notification "Certificate of Delivery" Form. Please fill in the blanks of the template with language to reflect your specific situation. Additionally, public water suppliers are required to submit a certification of delivery following any type of public notification to verify that all associated public notice activities have been completed in accordance with Regulation 11. The "Tier 1 Public Notice" must be reissued every two weeks until the Department has determined the distribution system is operating properly and providing safe drinking water to the public and has provided the Supplier with written correspondence rescinding the advisory.

In order to properly address the Boil/Bottle Water Advisory, the officials responsible for managing this public water system must:

- Correct the underlying problem.
- Flush the distribution system in consultation with the department.
- Obtain water samples from the affected areas of the distribution system in consultation with the department and have them analyzed for the presence of total coliform.

Upon completion of the above actions, the Supplier must provide the Department with a written description of the following activities:

- What the problem was and the actions taken to correct the underlying problem.
- Actions and procedures to flush the distribution system, to include:
 - Sampling performed and date/time of sampling.
 - Disinfection residual results.

In addition, the Supplier must provide the Department with copies of the following:

- "Certificate of Delivery" Form along with a copy of the Public Notice within ten (10) calendar days after each public notice distribution
- All laboratory and field monitoring results.

Please be advised, in the interest of protecting public health, the "Boil/Bottle Water Advisory" will not be rescinded until the Supplier has successfully completed the actions described above and received written notice (including email) authorizing the rescind of the advisory.

If you have any further questions, please contact me at 303-916-0240

or via email at tyson.ingels@state.co.us.

Sincerely,

Tyson Ingels

Lead Drinking Water Engineer
Water Quality Control Division
Colorado Department of Public Health and Environment

ec:

David Chapman - City of Englewood - DCHAPMAN@ENGLEWOODCO.GOV;
Josh Roach - City of Englewood - JRoach@englewoodco.gov;
Angela Goodman - City of Englewood - Deputy Director Utilities - agoodman@englewoodco.gov
Jennifer Charles - jcharles@tchd.org; Tri-County Health Dept
Brian Hlavacek - bhlavacek@tchd.org; Tri-County Health Dept
Michael Weakley - mweakley@tchd.org; Tri-County Health Dept
Nicole Rowan, Water Quality Control Division Director, CDPHE
Ron Falco, WQCD SDW Program Manager
Bret Icenogle, WQCD ES Manager
Heather Young, WQCD FSS Manager
Nicole Graziano, WQCD DWCAS Manager
Jorge Delgado, WQCD DWCAS Compliance North Unit Manager
Margaret Talbott, WQCD DWCAS Compliance South Unit Manager
MaryAnn Nason, WQCD Communications and Special Projects Unit Manager
Drinking Water Acute Response Team, WQCD
Deborah Nelson, Environmental Health and Protection Operations Manager, CDPHE
Greg Stasinis, Office of Emergency Preparedness and Response, CDPHE
Ann Nedrow, Office of Emergency Preparedness and Response, CDPHE
Pam Pergande, Office of Emergency Preparedness and Response, CDPHE
Rachel Jervis, DCPHR, CDPHE
Allison Wheeler, DCPHR, CDPHE

Mara Browsey-Wiwchar, Legislative Office, CDPHE
Shaun McGrathn, Director of Environmental Programs, CDPHE
Jessica Bralish, Communications Director, CDPHE

Bob Pohl - NORTH - B SW WQCD DWCAS Compliance Specialist

File: CO0103045, ARAPAHOE, Community - Surface Water